



Standard inspection checklist for Residential CSI's.

External property

- Identify auxiliary water supply sources. (private water wells, rainwater harvesting systems, ponds, creeks, stock tanks, lakes, rainwater retention, gray water collection systems)
- Swimming pool fill lines
- Landscape irrigation systems
- Insulation of appropriate backflow protection on faucet fixtures (HBVB, AVB & airgaps)
- On-site sewage facilities (OSSF)

Internal structure/residence

- Water closet installation / Overflow fill valve and anti-siphon unit.
- Hand held bath/kitchen hoses.
- Dishwasher
- Water filtering/softener equipment
- Any plumbing appurtenances utilizing potable water lines. (This will include post-consumer plumbing equipment add-ons.)

Lead copper inspection

- This inspection will be conducted both internal and external following CSI requirements. (see TCEQ CSI form).
- If plumbing appurtenance does not have the proper lead-free markings, it is the responsibility of the builder/residence to provide proof that the plumbing appurtenance meets TCEQ and EPA no lead guidelines. (Important to keep packaging material to validate appurtenance meets lead free requirements)

Note: This checklist is not intended to be all encompassing, but rather a list of the general items to be inspected during the course of a CSI.